

SECTION 10 81 00 – PEST CONTROL

PART 1 – GENERAL

1. Design Requirements, Pest Control:

- a. Stainless steel screening shall be provided at all concealed areas at crawlspaces, attic vents, exterior louvers, behind casework, and similar areas to prevent bird, rodent and insect infiltration.
- b. Integrated Pest Management (IPM) and Environmental Protection Agency (EPA) rules shall be considered.
- c. Pest control during construction shall be covered in General Conditions.
- d. Bird protection net or wire protection systems shall be used unless otherwise approved by a Brown University Project Manager. Please contact custodial services (Division 4) for information regarding the current vendor to be sure all issues are dealt with properly and in accordance with procedures.
- e. Wire spike systems (Nixalite) shall not be allowed for bird protection.

END OF SECTION