

SECTION 12000CP – FURNISHINGS, FABRICS, & SEATING

PART 1 - GENERAL

- 1.01 Any drapes, curtains, or soundproofing installed in business, dorm, and assembly occupancies, including classrooms seating 50 or more and library spaces, shall be specified as fire retardant/resistant, and submittals shall include evidence of compliance with NFPA 701. This information shall include acceptable test methods and labeling requirements.
- 1.02 All seating for use in public areas or assembly occupancies, including classrooms seating 50 or more and library spaces, shall meet the test criteria in the State of California, Bureau of Home Furnishings and Thermal Insulation Technical Bulletin Number 133, entitled "Flammability Test Procedure For Seating Furniture For Use In Public Occupancies," dated January 1991, or shall be tested in accordance with ASTM E 1537 93, "Standard Test Method for Fire Testing of Real Scale Upholstered Furniture Items," and meeting the test criteria of California Technical Bulletin 133.
- 1.02.1 The following label shall be attached to every article of seating complying with Technical Bulletin 133:
NOTICE: THIS ARTICLE IS MANUFACTURED FOR USE IN PUBLIC OCCUPANCIES AND MEETS THE FLAMMABILITY REQUIREMENTS OF CALIFORNIA BUREAU OF HOME FURNISHINGS TECHNICAL BULLETIN 133. CARE SHOULD BE EXERCISED NEAR OPEN FLAME OR WITH BURNING CIGARETTES.

END OF SECTION